


Belden 9538/9536 cable is required for the 12V power and data connections, with cable lengths up to 100m. Cat 5e - FTP cable can be used when cable lengths are less than 30 metres.

The shield/drain wires should be connected to earth at the control centre.

The use of other cable types may cause communication errors within systems using network accessories

An Automatic Bypass, or other equivalent product, should be installed at the manifold furthest from the heat source to allow the boiler to maintain a minimum flow rate, when demand from the systems emitters reduces.





Wavin, Underfloor Heating Division, Concorde House, Concorde Way, Segensworth North, Fareham, Hampshire, PO15 5RL

52UH108 - System Schematic

Only competent persons with certification recognised under Building Regulations - Part P should carry out electrical installation or servicing work.

All components must be installed and earthed in accordance with local regulations.

Power Supply - In